



Certificate of Compliance

Certificate: 1726044

Master Contract: 202993

Project: 2392662

Date Issued: February 28, 2011

Issued to: International Metal Engineering

Blk 13 Toa Payoh Lorong 8 06-05
Braddell Tech Park
Singapore, 319261
Singapore
Attention: Max Angelo Vijaya

The products listed below are eligible to bear the CSA Mark shown



Ron Wildish

Issued by: Ron Wildish

PRODUCTS

CLASS 4418 02 - OUTLET BOXES AND FITTINGS - Boxes - For Hazardous Locations

Class I, Div. 1, Groups B, C and D; Class II, Div. 1, Groups E, F and G, Class III, Div. 1; Type 4X:

Ex d IIB+H2:

7080a-b-c Junction Boxes - Epoxy coated cast aluminum, stainless steel with window or blind cover; Ambient: -40 Deg C to +85 Deg.C.

a = Model AE, AM, SE, SM, TE, TM, WE or WM.

b = Entry configuration 00, 01, 02, 03 or 04.

c = Entry Type: 05, 07 or 18

7080a-b-c Junction Boxes - Cast finish aluminum with window or blind cover; Ambient: -40 Deg C to +85 Deg.C.

a = Model CE, CM, NE or NM.

b = Entry configuration 00, 01, 02, 03 or 04.



Certificate: 1726044

Master Contract: 202993

Project: 2392662

Date Issued: February 28, 2011

c = Entry Type: 05, 07 or 18

8066a-b Instrument Enclosure - Epoxy coated cast Aluminum with window or blind cover; Ambient: -40 Deg C to +85 Deg.C.

a = Model PB or PD

b = Entry type: 04, 05, 07, 08, 13, 17, 18, 19 or 20

8075a-b Instrument Enclosures - Epoxy coated Cast Aluminum, stainless steel with window or blind cover; Ambient: -40 Deg C to +85 Deg.C.

a = Model AE, AM, SE, SM, TE, TM, WE or WM.

b = Entry type: 01, 02, 04, 05, 07, 08, 13, 15, 17 or 18

8080a-b Instrument Enclosures - Epoxy coated Cast Aluminum, stainless steel with window or blind cover; Ambient: -40 Deg C to +85 Deg.C.

a = Model AE, AM, SE, SM, TE, TM, WE or WM.

b = Entry type: 01, 02, 04, 05, 07, 08, 13, 15, 17 or 18

Conduit Entry Sizes Include: ½” NPT, ¾” NPT, M16x2P (Not Tapped Thru) or None.

APPLICABLE REQUIREMENTS

C22.2 No. 0-10 - General Requirements – Canadian Electrical Code, Part II

C22.2 No. 25-1966 - Enclosures for Use in Class II, Groups E, F and G Hazardous Locations

C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures

CAN/CSA-C22.2 No. 60079-0:07 - Electrical apparatus for explosive gas atmospheres - Part 0: General requirements

CAN/CSA-C22.2 No. 60079-1:07 - Electrical apparatus for explosive gas atmospheres - Part 1: Flameproof enclosures "d"

CAN/CSA-C22.2 No. 60529:05 - Degrees of protection provided by enclosures (IP Code)