

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

7100a-b-c. Series Junction Boxes.

a = Model AE, AM, CE, CM, NE, NM, WE or WM

b = Entry configuration 00, 01, 02, 03 or 04.

c = Entry size 05, 07, 18 or 22.

7100a-b-c. Series Stainless Steel Junction Boxes.

a = Model SE, SM, TE or TM.

b = Entry configuration 00, 01, 02, 03 or 04.

c = Entry size 05, 07, 18, 22 or 25.

8100a-b. Series Instrument Enclosure.

a = Model AE, AM, WE or WM.

b = Entry configuration 04, 05, 06, 07, 08, 09, 13, 14, 17, 18, 19, 20, 21 or 22.

8100a-b. Series Stainless Steel Instrument Enclosure.

a = Model SE, SM, TE or TM.

b = Entry configuration 04, 05, 06, 07, 08, 09, 13, 14, 17, 18, 19, 20, 21, 22, 25, 26, 27, 28, 30, 31, 32, 34 or 36.

8100PB-a. Series Instrument Enclosure.

a = Entry configuration 04, 05, 06, 07, 08, 09, 13, 14, 17, 18, 19, 20, 21 or 22.

8100PD-a. Series Instrument Enclosure.

a = Entry configuration 04, 05, 06, 07, 08, 09, 13, 14, 17, 18, 19, 20, 21 or 22.

Equipment Ratings:

Explosionproof for Class I, Division 1, Groups B, C and D; Dust-ignitionproof for Class II/III, Division 1, Groups E, F and G, hazardous (classified) locations, indoors and outdoors (Type 4X/IP66) and Ta = +85°C.

FM Approved for:

International Metal Engineering Pte Ltd Singapore



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	2011
Class 3615	2006
Class 3810	2005
ANSI/NEMA 250	1991
ANSI/IEC 60529	2004

Original Project ID: 3032880

Approval Granted: January 16, 2009

Subsequent Revision Reports / Date Approval Amended

Report Number

Date

Report Number

Date

3037386

November 10, 2009

141124

January 7, 2015

FM Approvals LLC

Manager, Electrical Systems

7 January 2015
Date