

FM Approvals 1151 Boston Providence Turnpike P.O. Box 9102 Norwood, MA 02062 USA T: **781 762 4300** F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

9080aM-b-c-d. Instrument Enclosures.

XP/I/1/BCD/Ta = -40° C to $+60^{\circ}$ C; DIP/II,III/1/EFG/Ta = -40° C to $+60^{\circ}$ C; Type 4X, IP66 a = Enclosure type WE, WM, AE, AM, SE, SM, TE or TM.

- b = Entry configuration 04, 05, 06, 07, 08, 09, 13, 14, 17, 18, 19, 20, 21, 22, 25, 26, 27, 28, 30, 31, 32, 34, 35, 36, 37, 38, 39, 40 or 42.
- c = Terminal block 00, 01, 04 or 10.
- d = Number of wires (two digits; maximum value = 10).

Conditions of Use

- 1. For models supplied with a terminal block, the enclosure's use is limited to a maximum of 35 Vdc/16 Vac, 5 A and 5.6 W.
- 2. The enclosure bottom or process entry (T1) requires a seal at the enclosure.

9080a-b-c. Indicator Assemblies.

XP/I/1/BCD/T6 Ta = -40°C to +60°C; DIP/II,III/1/EFG/T6 Ta = -40°C to +60°C; Type 4X, IP66 a = Electronics type EL, FR, HM, HT, MK, MN, PP, PR, PR1, PR2, PR3 or RR. b = Enclosure type A or T.

c = Entry configuration 04, 05, 06, 07, 08, 09, 13, 14, 17, 18, 19, 20, 21, 22, 25, 26, 27, 28, 30, 31, 32, 34, 35, 36, 37, 38, 39, 40 or 42.

Conditions of Use

- 1. The maximum supply voltage for all indicator assemblies is 35 Vdc.
- 2. The enclosure bottom or process entry (T1) requires a seal at the enclosure.

Page 1 of 3



9080Pa-b-c. Indicator Assemblies.

XP/I/1/BCD/T6 Ta = -40°C to +60°C; DIP/II,III/1/EFG/T6 Ta = -40°C to +60°C; Type 4X, IP66 a = Electronics type A or T. b = Enclosure type A or T. c = Entry configuration 04, 05, 06 or 31.

Conditions of Use

- 1. The maximum supply voltage for all indicator assemblies is 35 Vdc.
- 2. The enclosure bottom or process entry (T1) requires a seal at the enclosure.

Equipment Ratings:

Explosionproof for Class I, Division 1, Groups B, C and D and Dust-Ignitionproof for Class II, Division 1, Groups E, F and G, Class III, Division 1 hazardous (classified) locations, indoors and outdoors (Type 4X, IP66).

FM Approved for:

International Metal Engineering Pte Ltd Singapore



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

 Class 3600
 2011

 Class 3615
 2006

 Class 3616
 2011

 Class 3810
 2005

 ANSI/IEC 60529
 2004

 ANSI/NEMA 250
 2003

Original Project ID: 3049139

Approval Granted: August 27, 2013

Date

Subsequent Revision Reports / Date Approval Amended

Report Number Date Report Number

FM Approvals LLC

Marguerchit

L. E. Marquedant Group Manager, Electrical

27 August 2013

Date