

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: IECEx SIR 12.0151X

Page 1 of 4

Certificate history:

Status: Current

Issue No: 2

Issue 1 (2018-03-06) Issue 0 (2013-03-13)

Date of Issue: 2021-03-31

Applicant: IntInternational Metal Engineering Pte Ltd

Blk 13 Toa Payoh Lorong 8 #06-05 Braddell Tech Park Singapore 319261

Singapore

Equipment: 9080 Dual Compartment Indicator/Transmitter Assembly

Optional accessory:

Type of Protection: Flameproof and Dust Protection by Enclosure

Marking: Ex db IIC T6 Gb

Ex tb III C T85°C Db Ta = -40°C to +60°C

Approved for issue on behalf of the IECEx

Certification Body:

Neil Jones

Position:

Certification Manager

Signature:

(for printed version)

Date:

- 1. This certificate and schedule may only be reproduced in full.
- 2. This certificate is not transferable and remains the property of the issuing body.
- 3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

SIRA Certification Service CSA Group Unit 6, Hawarden Industrial Park Hawarden, Deeside, CH5 3US United Kingdom







Certificate No.: IECEx SIR 12.0151X Page 2 of 4

Date of issue: 2021-03-31 Issue No: 2

Manufacturer: International Metal Engineering Pte Ltd

Blk 13 Toa Payoh Lorong 8 #06-05 Braddell Tech Park Singapore 319261

Singapore

Additional manufacturing locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS:

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2011 Explosive atmospheres - Part 0: General requirements

Edition:6.0

IEC 60079-1:2014-06 Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d" Edition:7.0

IEC 60079-31:2013 Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t" Edition:2

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

GB/SIR/ExTR13.0024/00 GB/SIR/ExTR18.0013/00 GB/SIR/ExTR21.0026/00

Quality Assessment Report:

GB/SIR/QAR07.0040/08



Certificate No.: IECEx SIR 12.0151X Page 3 of 4

Date of issue: 2021-03-31 Issue No: 2

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The 9080 series dual compartment indicator/transmitter assemblies utilise the 9080 dual compartment housings, they are cylindrical, and comprising a base and two covers with an approximate internal volume of 450 cm 3 . The two compartments are separated by a central internal wall that may have one 8 mm thru hole for electronics. The electronics are secured with epoxy cement. The enclosures are manufactured from Copper-free Aluminium or Stainless Steel, the Copper-free Aluminium versions have an epoxy paint coating of maximum thickness 0.20 mm. The covers are either manufactured from Aluminium or Stainless Steel, and may be blind or comprise a tempered glass window. The housings can be populated with either a four post terminal block or a ten post semi-circle terminal block as specified in the manufacturer's documents.

The dual compartment indicator/transmitter assembly is populated with a loop powered indicator/transmitter as specified by the manufacturer. The maximum diameter of which shall not exceed 68 mm and the maximum power dissipation within the enclosure shall not exceed 5.6 W. The housings meet the requirements for degree of protection IP68.

Refer to the Annexe for additional information

SPECIFIC CONDITIONS OF USE: YES as shown below:

- 1. Under rated conditions, the cable entries may exceed 74°C; this shall be considered when installing the 9080 dual compartment indicator/ transmitter assembly. Only cables and cable glands that have temperature ratings suitable for the application shall be used.
- 2. The Copper-free Aluminium version has a non-conducting coating and may generate an ignition-capable level of electrostatic charge under certain extreme conditions. The user shall ensure that the equipment is not installed in a location where it may be subjected to external conditions (such as high-pressure steam) which might cause a build-up of electrostatic charges on non-conducting surfaces. Additionally, cleaning of the equipment should be done only with a damp cloth.



Certificate No.: IECEx SIR 12.0151X Page 4 of 4

Date of issue: 2021-03-31 Issue No: 2

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

This issue, Issue 2, recognises the following change; refer to the certificate annex to view a comprehensive history:

- 1. Remove all references to BSP thread types in the certificate product description and drawings, in relation to cable entry options, resulting in the removal of a condition in the certificate.
- 2. Removal of a Condition of Manufacture regarding the Ex component labelling.

Anney:

IECEx SIR 12.0151X Issue 2 Annexe.pdf

Annexe to: IECEx SIR 12.0151X Issue 2

Applicant: International Metal Engineering Pte Ltd



Apparatus: 9080 Dual Compartment

Indicator/Transmitter Assembly

Each enclosure may have a number of conduit openings and sizes refer to Table 2.

Table 2: 9080 Dual Compartment Indicator/Transmitter Assembly Design Options

Typic	al produ	ct refere	ence - 9080MK-A-04			
Code	Electronics Type					
MK	LED Loop Powered Indicator, Input 4-20 mA , Output: None					
PP	LCD Loop Powered Indicator, Input 4-20 mA, Output: None					
MN	LED Process Indicator, Power Supply 18 to 28 VDC, Input 4-20 mA, Output: None					
RR	LED Process Indicator with Dual alarms, Power Supply 18 to 28 VDC, 4-20 mA Input, 2 Relay Outputs, 4-20m/					
		smission				
PR				8 to 28 VDC, RTD, Thermocouple J,K Sensors		
	Input,	2 Relay C	outputs	·		
PR1	LED Te	mperatu	re Indicator with Dual Alarms, Power Supply 12	2 to 28 VDC, RTD, Thermocouple J,K Sensors		
		Input, 2 Relay Outputs, 4-20mA Retransmission Output				
PR2						
	Input, 2 Relay Outputs, PID Controlled Output					
PR3	Dual Channel, LED Temperature Indicator with Dual Alarms, Power Supply 12 to 28 VDC, RTD, Thermocouple					
	J,K Sensors Input, 2 Relay Outputs					
EL	LCD Loop Powered Indicator with Engineering Units Display, Input 4-20 mA, Output: None					
HT	LCD, 2 Wire, Indicating Temperature Transmitter + Hart, Power Supply 10.5 to 45 VDC, 4-20mA Output (loop)					
PA		+ Hart Communication Protocol				
PA	LCD, 2 Wire, Indicating Pressure Transmitter + Hart, Power Supply 10.5 to 45 VDC, 4-20mA Output (loop) + Hart Communication Protocol					
PT	LED Pressure Indicator with Dual alarms, Power Supply 18 to 28 VDC, 2 Relay Outputs					
FR		LED Flow Indicator and Totalizer with Dual alarms, Power Supply 18 to 28 VDC, 2 Relay Outputs LED Flow Indicator and Totalizer with Dual alarms, Power Supply 18 to 28 VDC, 4-20 mA/Pulse Input, 2 Relay Outputs,				
	4-20mA Retransmission Output					
НМ		Combination of LED Loop Powered Indicator + Head Mounted Transmitter.				
XX	Any specified Indicator/Transmitter with power dissipation less than 5.6W, Outer diameter less than 65mm and total					
	height less than 60mm					
	Code Enclosure Type					
	A Aluminum Enclosure					
	T Stainless Steel Enclosure		s Steel Enclosure			
		Code	T1	T2		
		04	½"NPT	34"NPT		
		05	½"NPT	½"NPT		
		06	½"NPT	M20 x 1.5P		
		07	34"NPT	3/4"NPT		
		08	34"NPT	½"NPT		
		09	34"NPT	M20 x 1.5P		
		13	3/4"NPT	None		
		14	M20 x 1.5P	None		
		17	½"NPT	None		
		18	None	None		
		19	None	34"NPT		
		20	None	½"NPT		
		21	None	M20 x 1.5P		
		22	M20 x 1.5P	M20 x 1.5P		
		25	M25 x 1.5P	½" NPT		
		26	M25 x 1.5P	3/4" NPT		
		27	M25 x 1.5P	M20 x 1.5P		
		41	IVIZU A LUF	IVIZU A T.JE		

Date: 31 March 2021 Page 1 of 2

Sira Certification Service

Unit 6 Hawarden Industrial Park, Hawarden, CH5 3US, United Kingdom

Tel: +44 (0) 1244 670900 Email: <u>ukinfo@csagroup.org</u> Web: <u>www.csagroupuk.org</u> Annexe to: IECEx SIR 12.0151X Issue 2

Applicant: International Metal Engineering Pte Ltd



Apparatus: 9080 Dual Compartment

Indicator/Transmitter Assembly

Code	T1	T2
28	M25 x 1.5P	M25 x 1.5P
30	M25 x 1.5P	None
31	½"NPT	M25 x 1.5P
32	34"NPT	M25 x 1.5P
34	M20 x 1.5P	M25 x 1.5P
35	1" NPT	M25 x 1.5P
36	NONE	M25 x 1.5P
37	1" NPT	1⁄2" NPT
38	1" NPT	3/4" NPT
39	1" NPT	M20 x 1.5P
40	1" NPT	M25 x 1.5P
42	1" NPT	None

A typical product reference would be 9080MK-A-04.

Conditions Of Manufacture

i. The equipment covered by this certificate incorporates previously certified devices; it is therefore the responsibility of the manufacturer to continually monitor the status of the certification associated with these devices, and the manufacturer shall inform CSA Sira of any modifications of the devices that may impinge upon the explosion safety design of the equipment.

Full Certificate Change History

Issue 1 – this Issue introduced the following changes:

- 1. Following appropriate assessment to demonstrate compliance with the latest technical knowledge, IEC 60079-1:2007 Ed.6 and IEC 60079-31:2008 Ed.1 were replaced by IEC 60079-1:2014 Ed.7 and IEC 60079-31:2013 Ed.2, the markings and conditions were updated accordingly to recognise the new standards.
- 2. Other external thread types (other than metric or NPT) are not permitted as an option for cable glands in field wiring installations in IEC 60079-1:2014 Annex C.2.2, therefore a specific condition of use is added to this certificate.

Page 2 of 2

Issue 2 – this Issue introduced the following changes:

- 1. Remove all references to BSP thread types in the certificate product description and drawings, in relation to cable entry options, resulting in the removal of a condition in the certificate.
- 2. Removal of a Condition of Manufacture regarding the Ex component labelling.

Sira Certification Service

Unit 6 Hawarden Industrial Park, Hawarden, CH5 3US, United Kingdom

Tel: +44 (0) 1244 670900 Email: <u>ukinfo@csagroup.org</u> Web: <u>www.csagroupuk.org</u>

31 March 2021

Date: