



Certificate of Compliance

Certificate: 1795392 **Master Contract:** 202993
Project: 80201929 **Date Issued:** 2024-09-18
Issued to: International Metal Engineering Pte Ltd
Blk 13 Toa Payoh Lorong 8
#06-05, Braddell Tech Park
Singapore, Central Singapore 319261
Singapore

Attention: Williams Williams

The products listed below are eligible to bear the CSA Mark shown



Issued by: Jerry Thai
Jerry Thai

PRODUCTS

Class 2258 02 PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Groups B, C and D; Class II, Groups E, F and G; Class III; Type 4X; T6.

Field Mounted Indicators

Model(s)	Voltage (VDC max)	Current (mA dc)	Conduit Size
8080MN, 8080PP, 8080RR	PS: 28	input signal: 4-20	1/2" NPT or 3/4" NPT

APPLICABLE REQUIREMENTS

CSA C22.2 No. 25:17 (Fourth Edition) (R2022) - Enclosures for use in Class II, Division 1, Groups E, F, and G hazardous locations

CSA C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations - General Instruction No 1-2

CSA C22.2 NO. 94.2:20 - Enclosures for electrical equipment, environmental considerations



Certificate: 1795392

Master Contract: 202993

Project: 80201929

Date Issued: 2024-09-18

CSA C22.2 NO. 142-M1987 -Third Edition - Process Control Equipment - General Instruction No. 1: May 1987; No. 2: June 1987; No. 3: June 1988; No. 4: February 1989; No. 5: September 1990

Markings

As per CSA Report 1795392 Markings Section.



Certificate: 1795392


Project: 80201929

Master Contract: 202993

Date Issued: 2024-09-18

Notes:

Products certified under Class(es) C225802 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 1795392

Master Contract: 202993

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80201929	2024-09-18	Update to CSA Report 1795392 to update C22.2 No. 25-1966 and C22.2 No. 94-M91 to their latest editions, C22.2 No. 25-17 (R2022) and C22.2 No. 94.2:20.
70052880	2016-02-25	Update to report 1795392 to cover drawing revisions per Factory Inspection report of August 1st, 2014 at Factory contract 202994.
1795392	2006-07-24	Original Certification: Models 8080RR, 8080MN and 8080PP for Class I, Grs B, C and D; Class II, Grs E, F and G, Class III hazardous locations.